



June 25, 2009

**ADDENDA NO. 2
TO THE
CONTRACT DOCUMENTS AND TECHNICAL SPECIFICATIONS
BID # 54-09
DAIRY RIDGE ROAD BRIDGE PROJECT**

The following revisions, additions, and clarifications are hereby made part of the Contract Documents and Technical Specifications for the above referenced project and shall be taken into account in the preparation of all bids and the execution of all work. Bidders shall acknowledge receipt of the addendum through signed copy of addendum delivered in person, fax, or signature e-mail.

REVISIONS/CLARIFICATION TO SPECIFICATIONS

Make the following additions to the plans and specifications:

1. As-builts" are required for the bridge structure and pavement grades.
2. Use SC DOT guardrail end treatment Type T. SC DOT standard detail 805-3.
3. Single solid white paint is required for the pavement edge. Double solid yellow paint is required for the road centerline. SC DOT Specification Section 625.
4. The County has some signage up already for closing the road. The contractor shall install signage per drawing 9.

5. Final finishes shall be per SC DOT specification section 702.
6. Riprap shall be class B per detail on drawing 6. Change the Miscellaneous Note on drawing 11 to Class B.
7. Section 01010-2 Summary of Work, should reference modified bulb tees and not cored slab.
8. Elastic Inclusion is referenced on page 1 of Special Provisions. Expanded polystyrene is mad by Team/IBS in Winchester, VA (or approved equivalent). (540) 931-1473. Geotextile separation fabric will be Geotex 1071 by Propex (or approved equivalent). Norris Supply has this material in Greenville, SC (864) 232-1876.
9. Bid specification 02000 Sections 17 and 18 were not included in the bid package. Please refer to SC DOT standards for paving and striping.

Respectfully Submitted,

Michael Emory, CPPB
Procurement Director
Spartanburg County
P.O Box 5666
Spartanburg, S.C. 29304
864-596-2519
864-596-2297 (fax)
e-mail memory@spartanburgcounty.org